Fiscal Year 2016 Cornell University Central Energy Plant (CEP) Fast Facts¹

| CEP PRIMARY ENERGY CONSUMPTION | | | |
|---|----------------------------|--------------|--|
| Primary Consumption (trillion Btu) | <u>1990 ⁽²⁾</u> | <u> 2016</u> | |
| Electricity (Grid Purchased) | 0.60 | 0.05 | |
| Coal | 1.33 | 0.00 | |
| Hydro (electric) | 0.02 | 0.02 | |
| Natural Gas | 0.28 | 3.02 | |
| Oil | 0.14 | 0.00 | |
| Total Primary Energy Consumption | 2.35 | 3.09 | |
| CENTRAL ENERGY PLANT EFFICIENCY | | | |
| Energy Output (trillion Btu) | 1990 | 2016 | |
| Total Steam Generation ⁽³⁾ | 1.35 | 1.30 | |
| Total Turbine Electric Generation | 0.07 | 0.88 | |
| Total Energy Output | 1.42 | 2.18 | |
| • · · · · · · · · · · · · · · · · · · · | | | |
| Fuel Sources (trillion Btu) | <u>1990</u> | <u>2016</u> | |
| Coal | 1.33 | 0.00 | |
| Natural Gas - Boilers | 0.28 | 0.09 | |
| Natural Gas - Turbines | 0.00 | 2.71 | |
| Natural Gas - Duct Burners | 0.00 | 0.21 | |
| Oil | 0.14 | 0.00 | |
| Total Energy Input (trillion Btu) | 1.74 | 3.02 | |
| Total Central Plant Efficiency | 81% | 72% | |
| Total Steam Sales (trillion Btu) | 0.99 | 0.83 | |
| Total Distrib and Building Steam Losses (%) | 17% | 19% | |
| Total Steam Condensed for Electric (trillion Btu) | 0.00 | 0.24 | |
| ELECTRICITY | 0.00 | 0.21 | |
| Cornell Utilities Generated (Mwh) | <u>1990</u> | <u> 2016</u> | |
| Cornell Utilities Hydro | 5,200 | 5,200 | |
| Cornell Utilities Steam Turbine - Cogen | 21,000 | 24,500 | |
| Cornell Utilities Gas Turbine - CCHPP(3) | 0 | 236,900 | |
| Total Cornell Utilities Generated | 26,200 | 266,600 | |
| Electricity Exported to Grid (Mwh) | 0 | (59,000) | |
| Electricity (Grid Purchased) (Mwh) | 174,500 | 11,600 | |
| Total CEP Electricity (Mwh) | 200,700 | 219,200 | |
| Total Campus Sales (Mwh) | 190,626 | 212,000 | |
| LSC Electricity (Grid Purchased) (Mwh) | . 0 | 4,400 | |
| Electricity (NY Grid) Sources | 1990 | 2016 | |
| Other Renewables | 0% | 5% | |
| Coal | 19% | 6% | |
| Natural Gas | 17% | 30% | |
| Hydro | 21% | 29% | |
| Nuclear | 17% | 29% | |
| Petroleum | 25% | 0% | |
| Other | 1% | 0% | |
| Total | 100% | 100% | |
| CHILLED WATER | | | |
| Energy Output & Input (trillion Btu) | <u>1990</u> | <u>2016</u> | |
| Total Chilled Water Production (trillion Btu) | 0.381 | 0.486 | |
| Total Energy Input (trillion Btu) ⁽⁶⁾ | 0.072 | 0.021 | |
| System Coefficient of Performance | 5.3 | 23.2 | |
| Total Campus Sales (trillion Btu) | 0.348 | 0.488 | |
| Chilled Water Sources | 050/ | 407 | |
| Mechanical Chillers | 85% | 1% | |
| Lake Source Cooling | 0% | 98% | |
| "Free" Cooling | 15% | 0% | |

| ENERGY RELATED CARBON DIOXIDE (CO ₂) | | |
|--|-------------------|----------------|
| Purchased Electric | <u>1990</u> | <u>2016</u> |
| Grid CO ₂ Emission Factor (kg/MWh) | 870 | 186 |
| Grid Electric CO ₂ (1,000 metric tons) | 152 | 3 |
| Cornell Central Energy Plant Cornell Coal ⁽⁴⁾ | 405 | 0 |
| Cornell Coal ⁽⁷⁾ Cornell Natural Gas ⁽⁵⁾ | 125 | 161 |
| Cornell Oil | 15 11 | 161 0 |
| Total CEP CO ₂ Emissions (1,000 metric tons) | 151 | 161 |
| Total CO ₂ Emissions (1,000 metric tons) | 303 | 164 |
| = | | |
| CO ₂ Emissions By Primary Energy Type: | 1990 | 2016 |
| Electricity (Grid Purchased) | 50% | 2% |
| On-Site Coal | 41% | 0% |
| On-Site Natural Gas | 5% | 98% |
| On-Site Oil | 4% | 0% |
| On-Site Hydro | 0% | 0% |
| | | |
| CENTRALLY CONNECTED BLDG GSF x 1,00 | | |
| 5 1 (| <u>1990</u> | <u>2016</u> |
| Electric (provided via CEP) | NA | 14,000 |
| Steam (provided via CEP) | NA | 12,800 |
| Chilled Water (provided via CEP) | NA | 8,700 |
| ENERGY METRICS (KBTU/GSF) PER YEAR | | |
| | 1990 | 2016 |
| Electric Sales | <u>7330</u> NA | 53 |
| Steam Sales | NA | 102 |
| Chilled Water Sales | NA | 56 |
| | | |
| ENERGY CONSUMPTION BY BUILDING | | |
| Building Type: (trillion Btu) | 1990 | 2016 |
| Research/Teaching | NA | 2.32 |
| Campus Life | NA | 0.56 |
| Administration | NA | 0.22 |
| | | |
| POPULATION AND WEATHER | | |
| 0 | <u>1990</u> | <u>2016</u> |
| Students Stoff/Non-Equility | 18,389 | 21,190 |
| Staff/Non-Faculty Faculty | 7,690 1,617 | 9,255 1,574 |
| Ithaca Campus ⁽⁶⁾ (1000 GSF) | 11,800 | 15,825 |
| Campus GSF per Student | 642 | 747 |
| Heating Degree Days (7,220 Normal) | 6,919 | 6,461 |
| Cooling Degree Days (337 Normal) | 312 | 392 |
| | | |
| GLOSSARY & NOTES | | |
| Btu: British thermal unit | | |
| Primary: Central Plant Usage | | |
| MMBtu: Million Btu | | |
| Mwh: mega watt-hour | | |
| (1) Info for CEP only, not all campus facilities part of CEP | | |
| (2) Kyoto Base Year is 1990 | | |
| (3) Combined Heat & Power Plant start-up FY 2010 | | |
| (4) "Beyond Coal" begins FY 2012 | | |
| (5) GHG NOT adjusted for exported electric | | |
| (6) Ithaca Campus GSF includes non-CEP conr | iected facilit | ies |