Fiscal Year 2021 Cornell University Central Energy Plant (CEP) Fast Facts¹

CEP PRIMARY ENERGY CONS		
Primary Consumption (trillion Btu)	1990 ⁽²⁾	<u>2021</u>
Electricity (Grid Purchased)	0.60	0.07
Coal	1.33	0.00
Hydro (electric)	0.02	0.02
Natural Gas	0.28	2.87
Oil _	0.14	0.01
Total Primary Energy Consumption	2.35	2.96
CENTRAL ENERGY PLANT EFFICIENCY		
Energy Output (trillion Btu)	1990	2021
Fotal Steam Generation ⁽³⁾	1.35	1.36
Total Turbine Electric Generation	0.07	0.83
Fotal Energy Output	1.42	2.18
_		
Fuel Sources (trillion Btu)	<u>1990</u>	<u>2021</u>
Coal	1.33	0.00
Natural Gas - Boilers	0.28	0.19
Natural Gas - Turbines	0.00	2.45
Natural Gas - Duct Burners	0.00	0.23
Oil _	0.14	0.01
Fotal Energy Input (trillion Btu)	1.74	2.88
Fotal Central Plant Efficiency	81%	76%
Fotal Steam Sales (trillion Btu)	0.99	0.83
Fotal Distrib and Building Steam Losses (%)	17%	23%
Total Steam Condensed for Electric (trillion Btu)	0.00	0.16
ELECTRICITY		
Cornell Utilities Generated (Mwh)	<u>1990</u>	2021
Cornell Utilities Hydro	5,200	4,900
Cornell Utilities Steam Turbine - Cogen	21,000	29,400
Cornell Utilities Gas Turbine - CCHPP (3)	0	212,400
otal Cornell Utilities Generated	26,200	246,700
Electricity Exported to Grid (Mwh)	0	(66,200)
Electricity (Grid Purchased) (Mwh)	174,500	13,400
Fotal CEP Electricity (Mwh)	200,700	193,900
Fotal Campus Sales (Mwh)	190,626	185,000
LSC Electricity (Grid Purchased) (Mwh)	0	6,000
Electricity (NY State Grid) Sources	<u>1990</u>	2021
Other Renewables	0%	7%
Coal	19%	1%
Natural Gas	17%	26%
Hydro	21%	35%
Nuclear	17%	31%
Petroleum	25%	1%
Other	1%	<1%
Total	100%	100%
CHILLED WATER		
	<u>1990</u>	2021
Energy Output & Input (trillion Btu)	0.381	0.563
		0.026
Total Chilled Water Production (trillion Btu)	0.072	
Fotal Chilled Water Production (trillion Btu) Fotal Energy Input (trillion Btu) ⁽⁶⁾	0.072 5.3	
Energy Output & Input (trillion Btu) Total Chilled Water Production (trillion Btu) Total Energy Input (trillion Btu) ⁽⁶⁾ System Coefficient of Performance Total Campus Sales (trillion Btu)		21.7
Total Chilled Water Production (trillion Btu) Total Energy Input (trillion Btu) ⁽⁶⁾ System Coefficient of Performance	5.3	21.7
Fotal Chilled Water Production (trillion Btu) Fotal Energy Input (trillion Btu) ⁽⁶⁾ System Coefficient of Performance Fotal Campus Sales (trillion Btu)	5.3	21.7 0.509
Fotal Chilled Water Production (trillion Btu) Fotal Energy Input (trillion Btu) ⁽⁶⁾ System Coefficient of Performance Fotal Campus Sales (trillion Btu) Chilled Water Sources	5.3 0.348	21.7 0.509 2% 98%

ENERGY RELATED CARBON DIOXIDE (CO ₂)	EMISSION	S
Purchased Electric	<u>1990</u>	2021
Grid CO ₂ Emission Factor (kg/MWh)	870	106
Grid Electric CO ₂ (1,000 metric tons)	152	2
Cornell Central Energy Plant		
Cornell Coal ⁽⁴⁾	125	(
Cornell Natural Gas ⁽⁵⁾	15	152
Cornell Oil	11	
Total CEP CO ₂ Emissions (1,000 metric tons)	151	153
Total CO ₂ Emissions (1,000 metric tons)	303	155
CO ₂ Emissions By Primary Energy Type:	<u>1990</u>	2021
Electricity (Grid Purchased)	50%	19
On-Site Coal	41%	0%
On-Site Natural Gas	5%	98%
On-Site Oil	4%	0%
On-Site Hydro	0%	0%
CENTRALLY CONNECTED BLDG GSF x 1,00	00	
	<u>1990</u>	2021
Electric (provided via CEP)	NA	14,000
Steam (provided via CEP)	NA	13,100
Chilled Water (provided via CEP)	NA	11,100
ENERGY METRICS (KBTU/GSF) PER YEAR		
· · ·	<u>1990</u>	2021
Electric (CEP to Campus)	NA	4
Steam (gross Generation)	NA	104
Chilled Water (gross Production)	NA	51
ENERGY CONSUMPTION BY BUILDING		
Building Type: (trillion Btu)	<u>1990</u>	2021
Research/Teaching	NA	2.20
Campus Life	NA	0.48
Administration (includes CEP)	NA	0.22
POPULATION AND WEATHER		
	<u>1990</u>	2021
Students	18,389	22,747
Staff/Non-Faculty	7,690	9,578
Faculty	1,617	1,543
Ithaca Campus ⁽⁶⁾ (1000 GSF)	11,800	16,02
0 005 01 1	642	704
Campus GSF per Student		6,768
Heating Degree Days (7,220 Normal)	6,919	0,700
·	6,919 312	
Heating Degree Days (7,220 Normal)		
Heating Degree Days (7,220 Normal) Cooling Degree Days (337 Normal)		725
Heating Degree Days (7,220 Normal) Cooling Degree Days (337 Normal) GLOSSARY & NOTES Btu: British thermal unit		
Heating Degree Days (7,220 Normal) Cooling Degree Days (337 Normal) GLOSSARY & NOTES Btu: British thermal unit Primary: Central Plant Usage MMBtu: Million Btu		
Heating Degree Days (7,220 Normal) Cooling Degree Days (337 Normal) GLOSSARY & NOTES Btu: British thermal unit Primary: Central Plant Usage MMBtu: Million Btu Mwh: mega watt-hour	312	
Heating Degree Days (7,220 Normal) Cooling Degree Days (337 Normal) GLOSSARY & NOTES Btu: British thermal unit Primary: Central Plant Usage MMBtu: Million Btu Mwh: mega watt-hour (1) Info for CEP only, not all campus facilities page	312	
Heating Degree Days (7,220 Normal) Cooling Degree Days (337 Normal) GLOSSARY & NOTES Btu: British thermal unit Primary: Central Plant Usage MMBtu: Million Btu Mwh: mega watt-hour (1) Info for CEP only, not all campus facilities page (2) Kyoto Base Year is 1990	312	
Heating Degree Days (7,220 Normal) Cooling Degree Days (337 Normal) GLOSSARY & NOTES Btu: British thermal unit Primary: Central Plant Usage MMBtu: Million Btu Mwh: mega watt-hour (1) Info for CEP only, not all campus facilities pa (2) Kyoto Base Year is 1990 (3) Combined Heat & Power Plant start-up FY 2	312	
Heating Degree Days (7,220 Normal) Cooling Degree Days (337 Normal) GLOSSARY & NOTES Btu: British thermal unit Primary: Central Plant Usage MMBtu: Million Btu Mwh: mega watt-hour (1) Info for CEP only, not all campus facilities page (2) Kyoto Base Year is 1990	312	